



ANTHONY AND LANGFORD / ARCHITECTS

12422 EAST WHITTIER BOULEVARD, WHITTIER, CALIFORNIA 90602 698-6271

January 5, 1970

City of Glendora  
116 East Foothill Blvd.  
Glendora, California 91740

Attention: Arthur E. Cook

Subject: Glendora Public Library


Gentlemen:

This is to approve the following deviations from the specifications on the above project.

1. Sec. 3A, page 3, Par. I states that form oil will not be allowed. Inasmuch as all exposed concrete is to receive a sandblast finish, we feel that form oil could be used if the Contractor so desires.
2. Sec. 3A, page 5, Par. E.2 states that either overlaid or lined plywood, form lining or metal pans are to be used for exposed concrete. Again, since exposed concrete is to receive a sandblast finish, plain plywood as specified may be used.
3. Sec. 3A, page 7, Par. L.1 states that stripping of footings, walls and pier forms shall not take place in less than five days. All forms could be removed as soon as concrete has sufficiently hardened so that damage would not result.
4. Footings may be poured against earth as long as excavations are straight and sloughing has not occurred. Excavations should be examined by the Building Department prior to pouring.

Very truly yours,

ANTHONY and LANGFORD/ARCHITECTS

  
E. Roger Willner, AIA

ERW:jc

cc: Earle T. Casler