

RUSS CONNORS ASSOCIATES

Consulting Structural Engineers

7801 Orangethorpe Avenue
BUENA PARK, CALIFORNIA 90620

Phone (213) 868-7764 (714) 522-2836

ANTHONY & LANGFORD
12422 WHITTIER BLVD
WHITTIER, CAL 90602
ATTN: ROGER WILLNER

Art Cook


DATE	3-23-71
PROJECT	GLENDORA LIBRARY
LOCATION	
CONTRACT NO.	
ISSUED	O'CAST
PREPARED BY	ROGER WILLNER EARL CASTLER PETE FARLEY CHRIS PRENTICE

- PERMISSION GIVEN TO POUR SLABS AFTER POURING JOISTS, BEAMS & GIRDERS, SUBJECT TO:
1. JOISTS & BEAMS HAVE 2x4 KEYS @ 32" O.C. EXCEPT FOR MIDDLE-THIRD OF SPANS.
 2. GIRDERS W/O KEYS
 3. ALL LAITANCE BE REMOVED BEFORE 2ND POUR.
 4. SLAB BE POURED WITHIN TWO DAYS FROM FIRST POUR.

IT WAS PROPOSED TO CREATE A STORAGE ROOM UNDER OUTSIDE STAIRS ON EAST SIDE. SLAB HAS 5' SPAN. OK TO HAVE 4" SLAB, W/#4@24 GW, DOWELED INTO WALLS.

SPANDREL ON WEST END OF LINE 4 WILL STOP AT LAST CONC. COL.

ARCH. WILL STUDY TOWER SHAFT WELL INTO CEILING'S. A STRUCTURAL STUDY WILL ALSO NECESSARY.



FIELD INSPECTION

SIGNED **B** B. HOFFMAN