



RUSS CONNORS ASSOCIATES
CONSULTING STRUCTURAL ENGINEERS

7801 DRANGETHORPE AVENUE • BUENA PARK, CALIFORNIA 90620 • PHONE (213) 868-7764 - (714) 522-2036

140 S. GLENDORA

M E S S A G E

TO ANTHONY & LANGFORD
12422 E WHITTIER BLVD
WHITTIER, CAL 90602
ATTN: ROGER WILNER

SUBJECT GLENDORA LIBRARY
JOB 70157

DATE 22 FEB 71

12 FEB 71

CONTRACTOR HAS REQUESTED TO HOLD SOFFITS OF SLABS LEVEL (PLAZA) WITHIN BOUNDARIES OF BEAMS, WHILE SLOPING THE TOP SURFACE ACCORDING TO PLAN. ASSUMING THIS TO BE APPROX 1" FALL, THIS MAY BE DONE, PROVIDED THE SLAB DEPTH, AS NOTED ON DRAWINGS, IS NOT DECREASED.

FEB 23 1971

BY BOB HOFFMAN

R E P L Y

DATE



SIGNED

INSTRUCTIONS TO SENDER:

1. KEEP YELLOW COPY. 2. SEND WHITE AND PINK COPIES WITH CARBON INTACT.

INSTRUCTIONS TO RECEIVER:

1. WRITE REPLY. 2. DETACH STUB, KEEP PINK COPY, RETURN WHITE COPY TO SENDER.