



City of Glendora | Community Development
 116 E. Foothill Blvd.
 Glendora, CA 91741

SELF CERTIFICATION OF INSTALLATION OF SMOKE/CARBON MONOXIDE ALARM(S)

The State of California requires smoke and carbon monoxide alarms to be installed in all residential occupancies, that contains, fuel-burning appliance, fireplace, forced-air furnace or an opening that communicates to an attached garage.

Property Address _____
 Owner Name _____ Permit Number _____
 Licensed Contractor: _____ License #: _____
 Total Number of Alarms Installed in Dwelling Unit(s): Smoke _____ Carbon Monoxide _____

When the valuation of additions, alterations, or repairs to existing dwelling units exceeds \$1000, Sections R310 and R311 of the California Residential Code requires that Smoke alarms and/or Carbon monoxide Alarms be installed in the following locations:

Smoke alarms are installed and functioning:	Carbon monoxide alarms are installed and functioning:
<ol style="list-style-type: none"> 1. In each sleeping room 2. Outside each separate sleeping area in the immediate vicinity of the bedrooms. 3. On each additional story of the dwelling, including basements and habitable attics but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level. 	<ol style="list-style-type: none"> 1. Outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedroom/s 2. On every level of a dwelling unit, including basements. 3. Where a fuel-burning appliance is located within a bedroom or its attached bathroom, a carbon monoxide alarm shall be installed within the bedroom

NOTE: Physical interconnection of alarms shall not be required where listed wireless alarms are installed and all alarms sound upon activation of one alarm.

Multi-purpose alarms: Carbon monoxide alarms combined with smoke alarms shall comply with sections R310 and 311 and shall be approved by the office of The State Fire Marshal.

Power Supply: Alarm(s) may be solely battery operated in buildings that are not served from a commercial power source. In existing dwelling units, alarms are permitted to be solely battery operated where repairs or alterations do not result in the removal of wall and ceiling finishes and there is no means of access by means of attic, basement, or crawl space. An electrical permit is required for alarms that must be connected to the building wiring.

As the owner of the above referenced Property, I hereby certify that the alarm(s) referenced above has/have been installed in accordance with the manufacturer’s instructions and in compliance with The California Residential Code. The alarms have been tested and are operational.

Print Name _____ Date _____
 Signature _____

ATTENTION PROPERTY OWNER: This is a voluntary self-certification verification procedure. If you prefer a City Building Inspector to perform the verification, you must arrange to have an adult present at the time of inspection and provide a ladder and access to locations of all alarms.

